

# Annual Drinking Water Quality Report – Village of Carbon Cliff, IL – IL1610100

CARBON CLIFF

IL 1610100

Annual Water Quality Report for the period of January 1 to December 31, 2018.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by CARBON CLIFF is Ground Water.

For more information regarding this report contact:

Jeff Welvaert, Water Operator – (309) 207-1049.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

## Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at

<http://www.epa.gov/safewater/lead>.

## Source Water Information

Source Water Name	Type of Water	Report Status	Location
WELL 1 (31850)	150 GPM	GW	<u>Pump House A – Carbon Cliff, IL</u>
WELL 2 (31851)	130 GPM - SUBMERSIBLE	GW	<u>Pump House A – Carbon Cliff, IL</u>
WELL 3 (01092)	ORCHARD LANE CARBON CLIFF	GW	<u>Pump House B – Carbon Cliff, IL</u>
WELL 4 (01093)	ORCHARD LANE CARBON CLIFF	GW	<u>Pump House B – Carbon Cliff, IL</u>

## Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by Village Hall or call our water operator at (309) 207-1049. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation / recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

### Source of Water: CARBON CLIFF

Based on information obtained in a Well Site Survey published in 1989 by the Illinois EPA, several potential sources are located within 1,000 feet of two of the wells. The Illinois EPA has determined that the Carbon Cliff Community Water Supply's source water is not suspectable to contamination. This determination is based on a number of criteria including; monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and available hydrogeologic data on the wells. Furthermore, in anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that the Carbon Cliff Community Water Supply is not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper siting conditions; a hydraulic barrier exists which should prevent pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. Because the community's wells are constructed in a confined aquifer, which should prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the susceptibility determination. Hence, well hydraulics were not evaluated for this system ground water supply.

## 2018 Regulated Contaminants Detected

### Lead and Copper

**Definitions:**

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# Sites Over All	Units	Violation	Likely Source of Contamination
Copper	09 / 28 / 2016	1.3	1.3	0.081	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09 / 28 / 2016	0	15	3.8	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

### Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

## Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/2018	1.9	1 - 2.7	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2018	2.1	0 - 2.1	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2018	0.15	0.058 - 0.15	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2018	11	6.3 - 11	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2018	0.799	0.678 - 0.799	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	2018	0.14	0.027 - 0.14		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Manganese	2018	3.6	1.8 - 3.6	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2018	0.07	0.04 - 0.07	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2018	8.9	2.3 - 8.9	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Sodium	2018	280	76 - 280			ppm	N	Erosion from naturally occurring deposits: Used in water softener regeneration.
Zinc	2018	0.027	0 - 0.027	5	5	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226 / 228	2018	8	0.989 - 11.6	0	5	pCi/L	Y	Erosion of natural deposits.
Gross alpha excluding radon and uranium	2018	9	0 - 12.2	0	15	pCi/L	N	Erosion of natural deposits.

## Violation Table

### Combined Radium 226 / 228

Some people who drink water containing radium 226 and 228 in excess of the MCL over many years may have an increased risk of getting cancer.

Violation Type  
MCL, Average

Violation Begin  
01/01/2018

Violation End  
03/31/2018

Violation Explanation  
Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.

Village of Carbon Cliff – IL1610100  
Annual Drinking Water Quality Report - January 1 to December 31, 2018

This year, as in years past, your tap water was tested according to United States Environmental Protection Agency (USEPA) and the Illinois Environmental Protection Agency (IEPA) Drinking Water Health Standards and Regulations. Our Water Department vigilantly safeguards its groundwater supply, and we are working hard to continue providing the best water possible. This report summarizes the quality of water that we provided for the year 2018.

Included in this report are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The Village is committed to providing you with information because informed customers are our best allies. During the 1st quarter monitoring period of 2018 (01/01/2018 to 03/31/2018), the Village Of Carbon Cliff Water System exceeded the standard or maximum contaminant level (MCL), for combined radium. The standard for combined radium is 5 pico curies per liter (pCi/L). The average level of combined radium in our system over the last year was 7 pCi/L. What is being done about this? The Village of Carbon Cliff has limited the amount of water put into service from Well #1 by blending it with water from Well #2 before going out into distribution for our residents. The Village has also taken additional samples to better monitor the levels of radium in our water system. The Village of Carbon Cliff has purchased and installed new meters and control valves for Wells #1 and #2 to provide reliable and consistent blending of finished water from TP01. Village of Carbon Cliff has reported quarterly radiological compliance samples from TP01, demonstrating that reprogrammed controls on new meters and control valves at the wells have enabled the water system to meet compliance with Maximum Contaminant Level (MCL) for Combined Radium at or below the Running Annual Average (RAA) 5 pCi/L. By October 10, 2018, the Village of Carbon Cliff had reported quarterly radiological compliance samples from TP01 to demonstrate compliance with the MCL for Combined Radium. The Village of Carbon Cliff has continued to report quarterly radiological compliance samples from TP01 for each of the reporting periods on January 10, 2019, and April 10, 2019 to demonstrate compliance with the MCL for Combined Radium. By April 10, 2019, Carbon Cliff has returned to compliance with the Maximum Contaminant Level Standard of 5 pCi/L for combined radium. All violations have been corrected, and Carbon Cliff has submitted a certification (or a statement) of compliance to IEPA.

If you have any questions about this report or questions concerning our water system, please contact the Village Hall at (309) 792-8235. We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our Public Works Committee Meetings at 6:00 p.m. the second Tuesday of every month or the Regular Meeting of the Carbon Cliff Board of Trustees on the first and third Tuesday of every month at 7:00 p.m. Both meetings are held at the Village Hall, 1001 Mansur Avenue, Carbon Cliff, Illinois. You may also visit the Village website at [www.Carbon-Cliff.com](http://www.Carbon-Cliff.com) for needed information.

Sincerely,  
Jeff Welvaert, Carbon Cliff Water Operator  
(309) 207-1049